
From: Jeffrey C Heffelman (Generation - 3) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=JEFFRE3]
Sent: 2/9/2015 6:06:24 PM
To: Ed Baine (Generation - 3) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Edwar62]
Subject: Fwd: Ash Pond ABC inspection 02/09/15
Attachments: 20150209171341126.pdf; ATT00001.htm

Sent from my iPhone

Begin forwarded message:

From: "Jeffrey R Marcell (Generation - 3)" <jeffrey.r.marcell@dom.com>
Date: February 9, 2015 at 5:13:29 PM EST
To: "Michael J Winters (Generation - 34)" <Michael.J.Winters@dom.com>
Cc: "John Cima (Generation - 34)" <john.cima@dom.com>, "Jeffrey C Heffelman (Generation - 3)" <Jeffrey.C.Heffelman@dom.com>, "Kenneth Roller (Services - 6)" <kenneth.roller@dom.com>
Subject: RE: Ash Pond ABC inspection 02/09/15
Attached.

No discharge at C Pond. No standing water.

Note: The seeping has decreased to a slow drip at the bottom NW corner.

No significant rainfall prior to inspection.

Let me know if you have any questions.

Jeff Marcell
Environmental Supervisor
Possum Point Power Station
Ladysmith & Remington CT Sites
703-441-3813 (phone)
8-795-3813 (tie)
703-441-3897 (fax)